

# **SEWER DEPARTMENT TOWN BOARD NOTES**

---

**09/ 08 / 2020**

## **Plant system.**

New sludge pump installed SBR #3 new 12" plug valve has been delivered just need to get it installed on SBR #3 so tank can be used when needed.

Alarm system on river road and 43 lift station has problem alarms will not clear from auto dialer I have Toric Engineering coming to check it out tomorrow.

## **Collection system.**

Damaged Manhole 46 west on YMCA Line has been replaced.

## **Other.**

N/A

**Notes by: John L. Hodge**